

इंटरनेट

मानक

Disclosure to Promote the Right To Information

Whereas the Parliament of India has set out to provide a practical regime of right to information for citizens to secure access to information under the control of public authorities, in order to promote transparency and accountability in the working of every public authority, and whereas the attached publication of the Bureau of Indian Standards is of particular interest to the public, particularly disadvantaged communities and those engaged in the pursuit of education and knowledge, the attached public safety standard is made available to promote the timely dissemination of this information in an accurate manner to the public.

“जानने का अधिकार, जीने का अधिकार”

Mazdoor Kisan Shakti Sangathan

“The Right to Information, The Right to Live”

“पुराने को छोड़ नये के तरफ”

Jawaharlal Nehru

“Step Out From the Old to the New”

IS 6399 (1971): Code of practice for construction of coffee seed storage structures [FAD 6: Stimulant Foods]



“ज्ञान से एक नये भारत का निर्माण”

Satyanarayan Gangaram Pitroda

“Invent a New India Using Knowledge”



“ज्ञान एक ऐसा खजाना है जो कभी चुराया नहीं जा सकता है”

Bhartrhari—Nitiśatakam

“Knowledge is such a treasure which cannot be stolen”

BLANK PAGE



IS : 6399 - 1971

(Reaffirmed 2012)

Indian Standard

CODE OF PRACTICE FOR CONSTRUCTION OF COFFEE SEED STORAGE STRUCTURES

UDC 624.953 : 633.73 : 631.243.36



© Copyright 1972

INDIAN STANDARDS INSTITUTION
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 1

Price Rs 2.00

Gr 2

April 1972

Indian Standard

CODE OF PRACTICE FOR CONSTRUCTION OF COFFEE SEED STORAGE STRUCTURES

Stimulant Foods Sectional Committee, AFDC 39

Chairman

SHRI C. P. NATARAJAN

Representing

Central Food Technological Research Institute
(CSIR), Mysore

Members

SHRI D. S. CHADHA	Central Committee for Food Standards, New Delhi
DR G. I. D'SOUZA	Central Coffee Research Institute, Chikmagalur
SHRI S. K. DUTTA	Tea Research Association, Calcutta
DR D. N. BARUA (<i>Alternate</i>)	
DR. K. K. IYA	The Coca-Cola Export Corporation, New Delhi
SHRI KISAN MEHTA (<i>Alternate</i>)	
DR M. K. K. IYENGAR	Food Specialities Limited, Moga
SHRI F. J. RYAN (<i>Alternate</i>)	
SHRI M. A. MANDANA	Coffee Board, Bangalore
SHRI B. KRISHNAMURTHY (<i>Alternate</i>)	
SHRI D. G. S. MARSH	Tea Packers Association of India, Calcutta
DR K. K. MITRA	Tea Board, Calcutta
DR B. D. NARANG	Public Analyst, Government of Haryana, Chandigarh
SHRI C. K. RAMNATH	Brooke Bond India Ltd, Calcutta
SHRI K. VENKATACHALAM (<i>Alternate</i>)	
DR G. S. RANDHAWA	Indian Council of Agricultural Research, New Delhi
SHRI T. A. SRIRAM (<i>Alternate</i>)	
DR V. BHALERAO (<i>Alternate</i>)	
Col R. R. RAO	Quartermaster General's Branch, Army Headquarters, New Delhi
Lt-Col O. P. KAPUR (<i>Alternate</i>)	
SHRI M. G. SATHE	The Sathe Biscuit and Chocolate Company Limited, Poona
SHRI R. D. SATHE (<i>Alternate</i>)	
SHRI B. B. UNWALA	Cadbury-Fry (India) Pvt Ltd, Bombay
SHRI B. J. CORK (<i>Alternate</i>)	
DR K. S. VENKATARAMANI	United Planters' Association of Southern India, Coonoor
DR C. S. VENKATA RAM (<i>Alternate</i>)	
DR HARI BHAGWAN, Director (Agri & Food)	Director General, ISI (<i>Ex-officio Member</i>)

Secretary

SHRI E. N. SUNDAR

Deputy Director (Agri & Food), ISI

INDIAN STANDARDS INSTITUTION
MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG
NEW DELHI 1

Indian Standard
**CODE OF PRACTICE FOR
CONSTRUCTION OF COFFEE SEED
STORAGE STRUCTURES**

0. FOREWORD

0.1 This Indian Standard was adopted by the Indian Standards Institution on 31 December 1971, after the draft finalized by the Stimulant Foods Sectional Committee had been approved by the Agricultural and Food Products Division Council.

0.2 The damage to coffee seeds due to fungal, microbial and insect attacks can be minimized to a large extent if coffee seeds are stored in structures which prevent, as far as practicable, their entry inside and also if suitable measures are taken during handling, transport and storage.

0.3 The damage and pollution of coffee seeds during storage are due to temperature, moisture and dampness, insects and rodents. It is therefore obvious that in order to conserve coffee seeds they should be stored in sound structures of different types, each type being suitable for a particular region in the country and code of practice should be formulated and adopted for handling, transporting and storing; when such standards become available and are implemented, they will go a long way in minimising the loss of coffee seeds.

0.4 This standard has been formulated mainly with a view to guiding processors, dealers and other agencies connected with handling of coffee seeds so that the damage to coffee seeds is, as far as possible, reduced to the minimum.

0.5 This code is designed for the construction of structures which would permit effective control of insect and other pests of stored coffee seeds and which would entirely exclude rain and ground moisture.

0.6 This standard has been formulated after a study of Indian Standards for foodgrains storage structures, but to suit the special requirements of coffee seed godowns.

0.7 Suggestions for the improvement of the existing warehouses have already been made by the Coffee Board. This code, therefore, has been prepared with a view to providing guidance to the upcoming coffee curing works and also in the construction of coffee storage structures in the future.

1. SCOPE

1.1 This standard specifies requirements and method for construction of coffee seed storage structures of the bag storage type.

1.2 It also specifies requirements and method of construction for storage structures intended to store cured coffee.

2. TERMINOLOGY

2.0 For the purpose of this standard, the following definitions shall apply.

2.1 Bag — A container made either of jute, fabric or laminates having the standard dimensions and containing a net content of 60 to 80 kg of cured coffee seeds.

2.2 Bag Storage Structure — Structure in which coffee seeds are stored in bags.

3. LOCATION

3.1 The coffee seed storage structure shall be located on a raised and well-drained site, or on suitably made-up soils, if necessary.

3.2 The structure shall not be located on lands subjected to floods or inundations and shall be safe from damage by surface or seepage water.

3.3 The structure shall be at least 15 m away from residential buildings, factories (other than coffee curing factories), dairies, poultry runs, kilns and other possible sources of fire and 30 m away from garbage, dumping grounds, slaughter houses, hide curing centres, tanneries and such other places, the close vicinity of which is deleterious to safe storage of coffee seeds.

NOTE — This shall not apply to any new structures which may be constructed within the premises of the existing curing works.

3.4 The structure shall be away from large trees.

3.5 The structure shall be generally accessible to lorries and preferably situated near a rail head with goods siding.

3.5.1 Where the structure is near waterways, such as ferry heads and docks sufficient berthing, loading and unloading facilities shall be made available.

4. BAG STORAGE STRUCTURES

4.1 The bag storage structure may be of dimensions most economically suited to the land available. The storage capacity shall be calculated taking

into account the coefficient factor as given below:

Coefficient factor — 0.7 m^2 per metric tonne of cured coffee seeds.

NOTE 1 — The coefficient factor is derived from: (a) 14 bags stacked one over the other, (b) each such bag containing 75 kg of coffee seeds, (c) 30 percent floor area for passage in between the stacks, and (d) stacks of 30 t bulk.

NOTE 2 — The minimum height of the wall may be 5.5 m for flat roofed structures and in the case of other structures the minimum wall height may be 4.25 m inside at the point where the roof crosses the wall.

5. FOUNDATION

5.1 The foundation shall be carried to a depth of not less than one metre unless rock, sheet-rock or laterite is met with at a higher level and shall have concrete bedding of suitable thickness unless rock, sheet-rock or laterite is met with.

5.2 The foundation masonry shall be of stone burnt bricks, concrete blocks or other suitable materials depending upon the availability of the same at a particular region. It shall be constructed either in lime mortar 1 : 3 (1 part lime and 3 parts of sand) or cement mortar of proportion not less than 1 : 5.

5.3 The foundation trenches on both sides shall be filled with coarse sand or gritty material and shall be flush with ground level.

5.4 Necessary measures shall be taken to make the structure termite-proof.

6. PLINTH

6.1 The plinth level shall be at a minimum height of 0.7 m from the surrounding ground level.

6.2 The plinth shall be filled up as given under 7.1.

6.3 The plinth (or basement) masonry shall be of stone in cement mortar of proportion not less than 1 : 5 and cement pointed 1 : 4 or plastered on its outer surface with cement plaster not less than 1 : 6.

6.4 There shall be laid 75 mm thick stone slab or 1 : 2 : 4 cement concrete plinth slab over the plinth masonry and below the superstructure.

7. FLOOR

7.1 Filling of Plinth or Basement — Fill with gritty moorum soil or red earth, sand or coal clinker. The layers should be of 75 mm up to a height of 150 mm in case of cement concrete floor or 225 mm in case of granite or any other good stone slabs floor, below the plinth level. Water profusely and compact each of these layers. Lay over these a layer of coarse sand and stone. Water and compact these layers of coarse sand and rubble stone and again compact these layers thoroughly.

7.2 Laying of the Floor — It shall be of either cement concrete, granite stone or any other good quality stone slabs. If the floor is of cement concrete it shall be 75 mm thick (25 mm thick 1 : 2 : 4 of 20 mm metal over 50 mm of 1 : 4 : 8 of 40 mm metal) and shall be laid in alternate panels, not exceeding 2.5 m². The joints of panels shall be neatly grouted with cement mortar 1 : 3. If the floor is of stone slabs, a layer of lime concrete or cement concrete 1 : 4 : 8 of 38 mm metal of not less than 75 mm thickness shall be laid over the 150 mm layer of rubble stone, over which the stone slabs shall be set in lime mortar 1 : 3 or cement mortar 1 : 4. The stone slabs shall not be less than 50 mm in thickness and shall be cement pointed 1 : 3.

8. WALLS

8.1 The walls shall be solid and not hollow and shall be at least 300 mm thick in the case of brick construction. In the case of laterite or other hard stone construction, the thickness of the wall shall be 450 mm up to a height of 3 m from the plinth and 225 mm thick from this height upwards. In the case of brick construction the walls shall be plastered with lime mortar 1 : 2 or cement mortar 1 : 4 shall be finished smooth. In case of laterite or stone construction cement mortar of 1 : 3 to 1 : 4 shall be used for pointing purpose. There shall be no off-sets or projections in the wall. The walls shall be flush with the outer surface of the plinth; in case this is not possible, the plinth projections shall be rounded off.

9. DOOR

9.1 The door opening shall be not less than 2 m wide and 2.5 m high. The door leaves shall be of steel or timber and either may be rolling type or opening outside. When open, the door leaves shall be flush with the outside surface of the wall. When closed, they shall be close fitting with the frame of the door. The door leaves shall not have cracks or open joints.

10. AIR VENTS

10.1 Air vents shall be provided at floor level for the ingress of fresh air. Windows shall not be provided.

10.2 The clear opening of the air vents should not be more than 35 cm², and shall be provided with shutters opening inside. When the godown abuts the road and safety considerations preclude the erection of air vents in the outer wall, they may be provided in the inner wall.

10.3 For every 5 m length of wall there shall be one air vent.

11. VENTILATORS

11.1 For every 6 m length of the wall, one ventilator of the size 0.7 m high and 1.2 m wide shall be provided. A centrally rotating shutter shall be

provided to the ventilator and the shutter shall be close fitting with the frame of the ventilator. The frame of the ventilator shall be fixed flush with the inside face of the wall.

11.2 The ventilator shall be protected by glazed sun shades and frame work of expanded metal or wire mesh.

12. ROOF

12.1 The roof may be either of reinforced concrete, flat, or shell roof; a sloping roof with asbestos cement sheets or Mangalore tiles, if the former is not available. The sloping roof shall be a single-span or two-span structure with a central longitudinal gutter which is a source of leakage. Galvanized steel sheets shall not be used.

12.1.1 The eaves of the roof shall project at least 0.7 m from the outer surface of the walls. The purlins and sheets shall be well anchored and secured.

13. DRAINAGE

13.1 Gutter and drain pipes shall be provided with the required dimensions taking into consideration the intensity of rainfall and the projected area of the roofing.

13.2 A stone or concrete slab of suitable dimensions shall be provided on the ground below each drain pipe so that the ground is not scoured due to the water falling from the drain pipe. The drain pipe shall be located in such a way that it shall not obstruct the ventilators.

13.3 All round the structure, abutting the plinth a pavement 0.5 m wide and 150 mm thick of lime concrete or cement concrete 1 : 3 : 6 or rubble stone pitching set in cement mortar 1 : 4 shall be constructed with suitable drainage arrangement. The pavement shall slope outside at 1 in 10.

14. UNDERGROUND DRAINAGE — BY RUBBLE DRAIN

14.1 Where ground water is likely to rise during the rainy season above the lowest level of the foundation, a trench 0.7 m wide shall be constructed all round the structure.

14.2 The trench shall be one metre away from the outer periphery of the structure, and shall be at the lowest level of the foundation with a longitudinal bed slope towards the natural fall of the ground. It shall be connected to an outfall drain for ultimate disposal of the water. It shall be filled with rubble or brick bats or graded jelly to a depth of 0.7 m and the rest with earth, and then levelled.

14.3 The rubble filling of the rubble drain should be so filled as to have the effect of an inverted filter, that is, bigger rubble should be put at the bottom and the size of rubble, brick bat or jelly to be reduced gradually.

NOTE — The specifications under **14** depend upon locality and site conditions may not be insisted upon in the case of inland region with rainfall of less than 750 mm. In coastal and heavy rainfall regions these are necessary, where the soil conditions require.

PUBLICATIONS OF INDIAN STANDARDS INSTITUTION

INDIAN STANDARDS

Over 6 500 Indian Standards covering various subjects have been issued so far. Of these, the standards belonging to the Agricultural and Food Products Group fall under the following categories:

Abattoir	Food additives
Alcoholic drinks	Food grain handling and storage
Animal feeds	Fruits and vegetables
Animal housing and equipment	Honey and by-products
Bakery and confectionery	Infant foods
Bee-keeping equipment	Laboratory animals
Beverages	Meat and meat products
Cereals, pulses and their products	Pest control equipment
Cocoa products	Pesticidal formulations
Coffee and its products	Pesticides, technical grade and general
Dairy equipment	Propagation materials
Dairy industry, layout plans	Regulated market yards
Dairy industry, methods of test	Sensory evaluation
Dairy laboratory apparatus	Spices and condiments
Dairy products	Starch derived products
Edible starch and starchy products	Sugars and by-products
Farm implements and machinery	Tea
Fish and fishery products	Tobacco products
Fish industry, sanitary conditions	Transport of live animals

OTHER PUBLICATIONS

ISI Bulletin (Published Every Month)					
Single Copy	...	...	...	...	Rs 3-00
Annual Subscription	...	...	...	...	Rs 25-00
Standards: Monthly Additions					
Single Copy	...	...	...	...	Rs 0-30
Annual Subscription	...	...	...	...	Rs 3-00
Annual Reports (from 1948-49 Onwards)				...	Rs 2-00 to 5-00
ISI Handbook, 1972				...	Rs 20-00

INDIAN STANDARDS INSTITUTION

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 1

Telephone : 27 01 31 (20 lines)

Telegrams : Manaksanstha

Branch Offices :

'Sadhna' Tulsivihar, Khanpur
F Block, Unity Bldg, Narasimharaja Square
534 Sardar Vallabhbhai Patel Road
5 Chowringhee Approach
5-9-201/2-A (First Floor), Chirag Ali Lane
117/418 B Sarvodaya Nagar
54 General Patters Road

	Telephone
Ahmedabad 1	—
Bangalore 2	2 76 49
Bombay 7	35 69 44
Calcutta 13	23-08 02
Hyderabad 1	5 34 35
Kanpur 5	82 72
Madras 2	8 72 78